



Vice President for Campus Planning, Infrastructure, and Facilities
 230 Sterrett Dr., Suite 112 (0127)
 Blacksburg, Virginia 24061
 Phone: 540/231-6291 Fax: 540/231-4745

STUDENT ORGANIZATION SUSTAINABILITY INITIATIVE PROPOSAL FORM

Part I- General Information:

| | |
|------------------------------|-----------------------------------|
| Name of Student Organization | Students for Sustainable Practice |
| Contact/Responsible Person | Erika Tuttobene |
| Contact Office Held/Title | Club Vice President |
| Contact Email Address | erikat27@vt.edu |
| Contact Telephone Number | (805) 720-0412 |

Part II- Project Cost Information

| | | |
|---------------------------------|---|------------------|
| Estimated Cost of this Proposal | \$10,250.60 | See III.C. below |
| Estimated Savings - | \$4,263.92 annually | See III.D. below |
| Net Cost of this Proposal = | \$10,250.60 with approximately 29 month period until return on investment | |

A. Please describe your sustainability initiative and attach supporting documentation.

Improve the energy efficiency of Lane Hall through the implementation of T8 LED lamps in existing corridor lighting fixtures. Lane Hall is Virginia Tech’s oldest building with significant historical value. Unfortunately, this means the building contains outdated and aging technologies that are not energy efficient. In order to help preserve this landmark and maintain progress towards Virginia Tech’s climate goals, lighting improvements should be made. By retrofitting existing lighting fixtures (see attachment 2), this low-cost, high-efficiency approach to introducing the building’s first LEDs will both reduce waste and spending associated with a full-replacement, and will avoid damage to the building.

B. How does this initiative help to achieve the goals of the Virginia Tech Climate Action Commitment Resolution and Sustainability Plan?

Sustainability Plan

- Supports goals outlined in the Climate Action Commitment and Policy Memorandum #262 amendments 1, 3, 4, 7, and 10
- Supports continuation of Point 4 - GHG Emissions Reduction through “Energy Usage”, and “Electrical Demand Response”
- Supports continuation of Point 7 - Energy Efficiency through “Lighting Retrofits and Occupancy Sensors”
- Supports continuation of Point 10 - Campus Engagement through “Student Involvement and Organizations”

Virginia Tech Policy #5505

- Supports goal of ensuring efficient energy use

Sustainability Annual Report 18-19

- Supports Point 4 - Improved Energy Efficiency through “Addressing Operational Inefficiencies” and “Retro-commissioning”

C. What is the cost of your proposal? Please describe in adequate detail the basis for your cost estimate.

Specifications & Key Notes

- State Electric Supply Company located in Christiansburg, VA is the current supplier for most Virginia Tech lighting and company representative Chris Caldwell provided cost estimates and calculators for project savings
- 61 2-tube lighting fixtures

Material Costs

- Cost of light + ballast for one tube Philips 9.5T8/MAS/48-840/IF16-P 10/1 (see attachment 3) \$9.18
- Cost of socket replacement (4 required per fixture) \$.89

$(122 \text{ tubes}) \times (\$9.18 \text{ lamp/ballast}) + (61 \text{ fixtures}) \times (4 \text{ sockets}) \times (\$.89 \text{ socket replacement}) = \mathbf{\$1,337.12}$

Labor Costs

With the assistance of Virginia Tech Facilities Services Energy Engineer Lowell Jessee, labor cost was calculated through an estimate of 1 hour per lighting fixture retrofit, totaling 61 hours. With an anticipated labor force of 2 contractors, paid at a rate of \$50 per hour, the following labor cost estimate was reached.

$(61 \text{ fixtures}) \times (1 \text{ hour}) + (2 \text{ contractors}) \times (\$50/\text{hour}) = \mathbf{\$6,100}$

Project Management & Contingency Budget Costs

With the assistance of Virginia Tech Facilities Services Energy Engineer Lowell Jessee, project management cost was calculated through an estimate of 15% of labor cost. An additional 15% of labor cost was factored to account for any unexpected costs that may arise. For example, needing to replace a lens that may be damaged during lamp replacement. A final 5% is factored for commissioning costs to ensure functionality. This could likely be handled by Virginia Tech's Engineering Services however, therefore external management may not be necessary.

$(\$6,100 \text{ labor}) \times (.15 \text{ project management budget}) + (\$6,100 \text{ labor}) \times (.15 \text{ contingency budget}) + (\$6,100 \text{ labor}) \times (.05 \text{ commissioning costs}) = \mathbf{\$2,135}$

Total Cost

$(\$2,015.60 \text{ material}) + (\$6,100 \text{ labor}) + (\$2,135 \text{ project management \& contingency}) = \mathbf{\$10,250.60}$

Reference Information

Chris Caldwell, State Electric Supply Co. : chris.caldwell@stateelectric.com, (540) 382-6415 x25061

Lowell Jessee, Virginia Tech Facilities Services, Engineering Operations : ljessee@vt.edu, (540) 231-7305

Wesley Linkous, Virginia Tech Facilities Services, Building Trades : wesleyll@vt.edu, (540) 231-4300

D. Will your proposal produce cost savings for the University? If so, how much? Please describe in adequate detail the basis for your savings estimate.

The proposed Philip LED lamps have a 250% lifetime improvement (70,000 hours compared to 20,000) expected in comparison to the current lamps (specified in documentation provided by State Electric Supply Co). By accounting for material replacement¹ and average of expected labor costs savings^{2 3} due to extended lamp lifetimes, an estimated annual \$316.80 in labor and \$472.78 in material savings can be expected (see attachment 5). The proposed lamps require 76.25% less wattage input than the existing (see attachment 4) (40w lamps to 9.5w lamps). Since the lights are run 24 hours a day, this change would amount to an annual energy savings of 34,733 kWh in electricity costs (\$3,474.34).

Adding all this up results in a total annual savings of \$4,263.92 for this project.

| | | |
|---|--|--------------------------------------|
| Prepared By: Erika Tuttobene Vice President - Students for Sustainable Practice Virginia Tech Class of 2021 erikat27@vt.edu (805) 720-0412 | | Date: November 23, 2020 |
| Lowell Jessee | | 11/30/20 |
| Reviewed By (Name of Appropriate University Official) | | Date |
| Denny Cochrane | | 11/30/20 |
| Reviewed By (Name of Office of Sustainability Representative) | | Date |



¹ "How to Calculate Material Savings from an LED Lighting Retrofit Project." *PKK Lighting Inc.*, 19 June 2019, www.pkklighting.com/how-to-calculate-material-savings-from-an-led-lighting-retrofit-project/.

² "Labor Savings from an LED Lighting Retrofit Project." *PKK Lighting Inc.*, 24 Mar. 2019, www.pkklighting.com/labor-savings-from-an-led-lighting-retrofit-project/.

³ Thomas, Andrew. "How to Calculate Labor Savings from a Lighting Retrofit: A Step-by-Step Guide." *Lighting Insights Blog*, Mar. 2017, insights.regencylighting.com/how-to-calculate-labor-savings-from-long-life-lighting-step-by-step-guide.

Attachment # 2

Examples of Lane Hall corridor lights, seen on all 3 floors.





T8

9.5T8/MAS/48-840/IF16/P 10/1

Product data

| General Information | |
|---------------------------------------|----------------------------------|
| Base | G13 [Medium Bi-Pin Fluorescent] |
| Nominal Lifetime (Nom) | 70000 h |
| Switching Cycle | 50000X |
| B50L70 | 70000 h |
| Light Technical | |
| Color Code | 841 [CCT of 4100K (841)] |
| Beam Angle (Nom) | 180 ° |
| Initial lumen (Nom) | 1600 lm |
| Luminous Flux (Rated) (Nom) | 1600 lm |
| Rated Beam Angle | 180 ° |
| Correlated Color Temperature (Nom) | 4000 K |
| Color Consistency | <6 |
| Color Rendering Index (Nom) | 80 |
| LLMF At End Of Nominal Lifetime (Nom) | 70 % |
| Product Data | |
| Order product name | 9.5T8/MAS/48-840/IF16/P 10/1 |
| EAN/UPC - Product | 046677473990 |
| Order code | 473990 |


| | |
|---------------------------------|----------------|
| Starting Time (Nom) | 0.5 s |
| Warm Up Time to 60% Light (Nom) | 0.5 s |
| Power Factor (Nom) | 0.9 |
| Voltage (Nom) | 120-277, 347 V |

| Temperature | |
|----------------------|--------|
| T-Ambient (Max) | 55 °C |
| T-Ambient (Min) | -20 °C |
| T-Storage (Max) | 65 °C |
| T-Storage (Min) | -40 °C |
| T-Case Maximum (Nom) | 55 °C |

| Controls and Dimming | |
|----------------------|----|
| Dimmable | No |

| Mechanical and Housing | |
|---------------------------------|--------------|
| Product Length | 1200 mm |
| Numerator - Quantity Per Pack | 1 |
| Numerator - Packs per outer box | 10 |
| Material Nr. (12NC) | 929002016004 |
| Net Weight (Piece) | 0.220 kg |
| Model Number | 9290020160 |

Dimensional drawing



TLED 1200mmT8 120-277 9.5W 1600lm 4000K

| Product | D1 | D2 | A1 | A2 | A3 |
|------------------------------|---------|-------|-----------|-----------|-----------|
| 9.5T8/MAS/48-840/IF16/P 10/1 | 25.7 mm | 28 mm | 1198.1 mm | 1205.2 mm | 1212.3 mm |

Philips. (2019) 9.5T8/MAS/48-840/IF16/P 10/1

<https://rexel-cdn.com/Products/EA2E326C-127B-432E-8FFF-9E86F9C2207A/EA2E326C-127B-432E-8FFF-9E86F9C2207A.pdf>



High CRI T12

F40T12 DX ALTO

Product data

• General Characteristics

| | |
|------------------------------|---|
| Base | Medium Bi-Pin [Medium Bi-Pin Fluorescent] |
| Base Information | Green Base |
| Bulb | T12 |
| Rated Avg. Life [3 hr Start] | 20000 hr |
| Energy Saving | Not Applicable |
| Life with 3h/day use [years] | 7 an |

• Light Technical Characteristics

| | |
|-----------------------|-----------------|
| Color Code | 57 |
| Color Rendering Index | 90 Ra8 |
| Color Designation | Daylight Deluxe |
| Color Temperature | 6500 K |
| Initial lumen | 2325 Lm |
| Design Mean Lumens | 2025 Lm |

• Electrical Characteristics

| | |
|-------|------|
| Watts | 40 W |
|-------|------|

• Environmental Characteristics


| | |
|----------------------|--------|
| Mercury (Hg) Content | 4.4 mg |
|----------------------|--------|

• Product Dimensions


| | |
|-----------------------|----|
| Nominal Length [inch] | 48 |
|-----------------------|----|

• Product Data

| | |
|--------------------|-------------------|
| Product number | 273599 |
| Full product name | F40T12 DX ALTO |
| Short product name | F40T12 DX ALTO/30 |
| Pieces per Sku | 1 |
| eop_pck_cfg | 30 |
| Skus/Case | 30 |
| Bar code on pack | 46677273590 |
| Bar code on case | 50046677273595 |
| Logistics code(s) | 927888005709 |
| eop_net_weight_pp | 0.001 kg |



G13



F40T12 DX ALTO

Philips. (2014) F40T12 DX ALTO

https://a89b8e4143ca50438f09-7c1706ba3fabeeda794725d88e4f5e57.ssl.cf2.rackcdn.com/spec_sheets/files/000/000/547/original/philips-273599-specs_1.pdf?1440219246



Lighting Upgrade Worksheet

| | | | | | | | | | |
|--|------------------------|--------------------------|------|----------------------------------|----------------|-----------------|---------------------------|------|------------------------------|
| Prepared for: | Lane Hall Green RFP | | | | Prepared by: | Erika Tuttobene | | | |
| City: | Blacksburg | State: | VA | Phone #: | (805) 720-0412 | | | | |
| kWh rate: | \$ 0.10 | | | | | | | | |
| Area/Space: | Lane Hall Corridors | | | | | | | | |
| Description of existing fixture: | T12 2-tube Fluorescent | | | | | | | | |
| Existing fixture wattage: | 86 | | | | | | | | |
| Existing quantity: | 61 | | | | | | | | |
| Description of new fixture: | T8 2-tube LED | | | | | | | | |
| New fixture wattage: | 21 | | | | | | | | |
| New quantity: | 61 | | | | | | | | |
| Annual operating hours: | 8,760 | | | | | | | | |
| No. fixtures with sensor/control: | - | | | | | | | | |
| KW controlled by sensor/control: | - | | | | | | | | |
| Sensor/Control reduction in on-hours: | 0% | 0% | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| Sensor/Control cost energy savings: | \$ - | \$ - | \$ - | \$ - | \$ - | \$ - | \$ - | \$ - | \$ - |
| Annual operating hours: | 8,760 | | | | | | | | |
| No. fixtures with sensor/control: | - | | | | | | | | |
| KW controlled by sensor/control: | - | | | | | | | | |
| Sensor/Control reduction in on-hours: | 0% | 0% | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| Sensor/Control cost energy savings: | \$ - | \$ - | \$ - | \$ - | \$ - | \$ - | \$ - | \$ - | \$ - |
| KW saved: | 3.97 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |
| kWh saved: | 34733.40 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |
| Annual savings: | \$ 3,473.34 | \$ - | \$ - | \$ - | \$ - | \$ - | \$ - | \$ - | \$ - |
| | Total Annual KW saved | Total Annual kWh saved | | Total Annual Energy Cost Savings | | | Annual Labor Cost Savings | | Annual Material Cost Savings |
| | 3.97 | 34,733 | | \$ 3,473.34 | | | \$ 316.80 | | \$ 472.78 |
| | Total Material Cost | Total Labor Cost | | Utility Incentives | | | Other Incentives | | |
| | \$ 1,337.12 | \$ 6,100.00 | | \$ - | | | \$ - | | |
| | Payback (years): | 1.74 | | Payback (months): | | | 20.94 | | |
| Equivalent tons CO ₂ removed: | 28 | | | | | | | | |
| Equivalent to CO ₂ emissions from the electricity used by | 3 | homes for one year. | | | | | | | |
| Equivalent greenhouse gas emissions from | 5 | passenger cars per year. | | | | | | | |
| www.stateelectric.com | | | | | | | | | |

Above is a Lighting Upgrade Worksheet provided by vendor State Electric Supply Company. This assisted in calculations of energy savings and payback period for the proposed lighting retrofit. While Virginia Tech pays closer to \$.095 per kWh of energy, for purposes of this document this cost was rounded up to \$.10 per kWh. Note that estimated payback period on document does not account for project management and contingency budget costs. The actual lighting project total is \$10,250.60, therefore estimated payback period is 2.4 years or just under 29 months.

Attachment #5 (cont.)

Labor savings were calculated using recommendation from Regency Lighting's estimating guidelines. If an assumed 10 minutes is required to change a lamp, and labor is compensated at a rate of \$50 per hour (\$8.30 per lamp), which is consistent with project labor requirement estimates, then labor savings can be calculated by how often the replacement of a lamp is required.

Existing lamps (see attachment 4):

$(8,760 \text{ hours per year}) / (20,000 \text{ hour lifetime of current lamps}) = .44 \text{ lamp replacements required per year}$
 $(.44 \text{ annual replacements}) \times (122 \text{ lamps}) = 53.44 \text{ replacements annually for all Lane Hall corridor lights}$
 $(53.44 \text{ replacement lamps}) \times (\$8.30 \text{ per lamp in labor}) = \mathbf{\$443.52 \text{ in total current annual labor costs}}$

Proposed lamps:

$(8,760 \text{ hours per year}) / (70,000 \text{ hour lifetime of proposed lamps}) = .13 \text{ lamp replacements required per year}$
 $(.13 \text{ annual replacements}) \times (122 \text{ lamps}) = 15.27 \text{ replacements annually for all Lane Hall corridor lights}$

$(15.27 \text{ replacement lamps}) \times (\$8.30 \text{ per lamp in labor}) = \mathbf{\$126.72 \text{ in proposed annual labor costs}}$

$(\$443.52 \text{ current estimated labor costs}) - (\$126.72 \text{ proposed estimated labor costs}) = \mathbf{\$316.80 \text{ in labor savings}}$

Material savings were calculated using costs from State Electric Supply Company. Savings were calculated by frequency of replacement, and replacement of ballast was factored into the cost as well.

Existing Lamps:

$(8,760 \text{ hours per year}) / (20,000 \text{ hour lifetime of current lamps}) = .44 \text{ lamp replacements required per year}$
 $(.44 \text{ annual replacements}) \times (122 \text{ lamps}) = 53.44 \text{ replacements annually for all Lane Hall corridor lights}$
 $(53.44 \text{ replacement lamps}) \times (\$11.47 \text{ per lamp/ballast}) = \mathbf{\$612.96 \text{ in total current annual material costs}}$

Proposed Lamps:

$(8,760 \text{ hours per year}) / (70,000 \text{ hour lifetime of proposed lamps}) = .13 \text{ lamp replacements required per year}$
 $(.13 \text{ annual replacements}) \times (122 \text{ lamps}) = 15.27 \text{ replacements annually for all Lane Hall corridor lights}$
 $(15.27 \text{ replacement lamps}) \times (\$9.18 \text{ per lamp/ballast}) = \mathbf{\$140.18 \text{ in proposed annual material costs}}$

$(\$612.96 \text{ in total current estimated annual material costs}) - (\$140.18 \text{ in proposed estimated annual material costs}) = \mathbf{\$472.78 \text{ in proposed annual material savings}}$

Total Annual Savings

$(\$316.80 \text{ labor}) + (\$472.78 \text{ material}) + (\$3,474.34 \text{ energy}) = \mathbf{\$4,263.92}$